

INSTALLATION GUIDE

STEP 1: INSTALL FLASHING

At desired location, use a flat bar or shingle tool to loosen the shingles that the flashing will slide under. Backfill each pilot hole with roofing sealant, and apply a U-shaped bead of roof sealant with the open side pointing downslope onto the flashing. Then slide the flashing into place under the shingle course, aligning the flashing hole. Pilot holes are not required when installing directly to the roof deck. When installing into a rafter, be sure to drill a 3/16" pilot hole.



LOOSEN SHINGLES



APPLY SEALANT



PLACE FLASHING



STEP 2: INSTALL CONDUIT MOUNT

Place **Conduit** Mount onto flashing so that the pre-installed EPDM grommet properly seats against the raised hole in the flashing. Once the **Conduit** Mount is in place, insert the included 5/16" x 2" lag screw through the mount and flashing into the pilot hole (if applicable), and tighten until the EPDM in the sealing washer bulges. Be sure not to over tighten.

STEP 3: INSTALL CONDUIT

Once **Conduit** Mount is installed on the roof, lay conduit into the **Conduit** Mount, then snap the cap into place, securing the conduit. Snap the cap into the first notch for 1" conduit and the second notch for 3/4" conduit.

TIPS:

RAIL MOUNTING: **Conduit** Mounts can also be installed in the **Solarmount** rail slot by using a 3/8" x 3/4" T-Bolt (sold separately) inserted through the **conduit** mount and secured when nut is tightened.

CAP REMOVAL: Cap can be removed from conduit by inserting a flat head screw driver into slot in the cap, and prying gently until cap clears notch in the base.

SPANS: See span tables for recommended attachment spans based on ground snow load for conduit runs horizontal to the roof ridge.

UL 2239 LISTED

Conduit Mount conforms to UL Standard 2239 "Hardware for the Support of Conduit, Tubing, and Cable" requirements. Load rating for 3/4" Conduit: 30 lb [14kg]; Load rating for 1" Conduit: 40 lb [18kg]; Temperature rating: -40°F to 194°F [-40°C to 90°C]. Suitable for wet locations and max 3.05m (10ft) support interval.



RAIL MOUNTING



CAP REMOVAL

EVERYTHING YOU NEED FOR A QUICK, PROFESSIONAL INSTALLATION

FOR QUESTIONS OR CUSTOMER SERVICE VISIT UNIRAC.COM OR CALL (505) 248-2702

CONDUIT MOUNT SPANS

MAXIMUM ATTACHMENT SPACING TO ROOF DECK (FT.) GROUND SNOW = 5 PSF												
DIST. TO RIDGE (FT)	ROOF PITCH											
	1:12	2:12	3:12	4:12	5:12	6:12	7:12	8:12	9:12	10:12	11:12	12:12
2	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
4	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
6	10.0	10.0	10.0	10.0	10.0	10.0	10.0	7.5	6.8	7.2	8.2	10.0
8	10.0	10.0	10.0	10.0	10.0	10.0	7.5	5.6	5.1	5.4	6.1	7.7
10	10.0	10.0	10.0	10.0	10.0	9.8	6.0	4.5	4.0	4.3	4.9	6.1
12	10.0	10.0	10.0	10.0	10.0	8.2	5.0	3.7	3.4	3.6	4.1	5.1
14	10.0	10.0	10.0	10.0	10.0	7.0	4.3	3.2	2.9	3.0	3.5	4.4
16	10.0	10.0	10.0	10.0	10.0	6.1	3.7	2.8	2.5	2.7	3.0	3.8
18	10.0	10.0	10.0	10.0	10.0	5.4	3.3	2.5	2.2	2.4	2.7	3.4
20	10.0	10.0	10.0	10.0	10.0	4.9	3.0	2.2	2.0	2.1	2.4	3.0

MAXIMUM ATTACHMENT SPACING TO RAFTER (FT.) GROUND SNOW = 5 PSF												
DIST. TO RIDGE (FT)	ROOF PITCH											
	1:12	2:12	3:12	4:12	5:12	6:12	7:12	8:12	9:12	10:12	11:12	12:12
2	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
4	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
6	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
8	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
10	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	9.4	10.0
12	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	8.7	10.0
14	10.0	10.0	10.0	10.0	10.0	10.0	10.0	9.9	7.4	6.7	7.1	10.0
16	10.0	10.0	10.0	10.0	10.0	10.0	10.0	8.7	6.5	5.9	6.2	8.9
18	10.0	10.0	10.0	10.0	10.0	10.0	7.7	5.8	5.2	5.5	6.3	7.9
20	10.0	10.0	10.0	10.0	10.0	10.0	6.9	5.2	4.7	4.9	5.7	7.1

MAXIMUM ATTACHMENT SPACING TO ROOF DECK (FT.) GROUND SNOW = 10 PSF												
DIST. TO RIDGE (FT)	ROOF PITCH											
	1:12	2:12	3:12	4:12	5:12	6:12	7:12	8:12	9:12	10:12	11:12	12:12
2	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
4	10.0	10.0	10.0	10.0	10.0	10.0	10.0	7.5	5.6	5.1	5.4	7.7
6	10.0	10.0	10.0	10.0	10.0	8.2	5.0	3.7	3.4	3.6	4.1	5.1
8	10.0	10.0	10.0	10.0	10.0	6.1	3.7	2.8	2.5	2.7	3.0	3.8
10	10.0	10.0	10.0	10.0	10.0	4.9	3.0	2.2	2.0	2.1	2.4	3.0
12	10.0	10.0	10.0	10.0	10.0	4.1	2.5	1.8	1.7	1.8	2.0	2.5
14	10.0	10.0	10.0	10.0	10.0	3.5	2.1	1.6	1.4	1.5	1.7	2.2
16	10.0	10.0	10.0	10.0	10.0	3.0	1.8	1.4	1.2	1.3	1.5	1.9
18	10.0	10.0	10.0	10.0	10.0	2.7	1.6	1.2	1.1	1.2	1.3	1.7
20	10.0	10.0	10.0	10.0	9.5	2.4	1.5	1.1	1.0	1.0	1.2	1.5

MAXIMUM ATTACHMENT SPACING TO RAFTER (FT.) GROUND SNOW = 10 PSF												
DIST. TO RIDGE (FT)	ROOF PITCH											
	1:12	2:12	3:12	4:12	5:12	6:12	7:12	8:12	9:12	10:12	11:12	12:12
2	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
4	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
6	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	8.7	7.8	10.0
8	10.0	10.0	10.0	10.0	10.0	10.0	10.0	8.7	6.5	5.9	6.2	8.9
10	10.0	10.0	10.0	10.0	10.0	10.0	10.0	6.9	5.2	4.7	4.9	7.1
12	10.0	10.0	10.0	10.0	10.0	10.0	9.5	5.8	4.3	3.9	4.1	5.9
14	10.0	10.0	10.0	10.0	10.0	8.1	4.9	3.7	3.3	3.5	4.0	5.1
16	10.0	10.0	10.0	10.0	10.0	7.1	4.3	3.2	2.9	3.1	3.5	4.4
18	10.0	10.0	10.0	10.0	10.0	6.3	3.8	2.9	2.6	2.7	3.1	3.9
20	10.0	10.0	10.0	10.0	10.0	5.7	3.4	2.6	2.3	2.4	2.8	3.5

MAXIMUM ATTACHMENT SPACING TO ROOF DECK (FT.) GROUND SNOW = 25 PSF												
DIST. TO RIDGE (FT)	ROOF PITCH											
	1:12	2:12	3:12	4:12	5:12	6:12	7:12	8:12	9:12	10:12	11:12	12:12
2	10.0	10.0	10.0	10.0	10.0	9.8	6.0	4.5	4.0	4.3	4.9	6.1
4	10.0	10.0	10.0	10.0	10.0	4.9	3.0	2.2	2.0	2.1	2.4	3.0
6	10.0	10.0	10.0	10.0	10.0	3.2	2.0	1.5	1.3	1.4	1.6	2.0
8	10.0	10.0	10.0	10.0	9.5	2.4	1.5	1.1	1.0	1.0	1.2	1.5
10	10.0	10.0	10.0	10.0	7.6	1.9	1.2	0.9	0.8	0.8	0.9	1.2
12	10.0	10.0	10.0	10.0	6.3	1.6	1.0	0.7	0.6	0.7	0.8	1.0
14	10.0	10.0	10.0	10.0	5.4	1.4	0.8	0.6	0.5	0.6	0.7	0.8
16	10.0	10.0	10.0	10.0	4.7	1.2	0.7	0.5	0.5	0.5	0.6	0.7
18	10.0	10.0	10.0	10.0	4.2	1.0	0.6	0.5	0.4	0.4	0.5	0.6
20	10.0	10.0	10.0	10.0	3.8	0.9	0.6	0.4	0.4	0.4	0.4	0.6

MAXIMUM ATTACHMENT SPACING TO RAFTER (FT.) GROUND SNOW = 25 PSF												
DIST. TO RIDGE (FT)	ROOF PITCH											
	1:12	2:12	3:12	4:12	5:12	6:12	7:12	8:12	9:12	10:12	11:12	12:12
2	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	9.4	9.9	10.0
4	10.0	10.0	10.0	10.0	10.0	10.0	6.9	5.2	4.7	4.9	5.7	7.1
6	10.0	10.0	10.0	10.0	10.0	10.0	7.6	4.6	3.4	3.1	3.3	4.7
8	10.0	10.0	10.0	10.0	10.0	10.0	5.7	3.4	2.6	2.3	2.4	3.5
10	10.0	10.0	10.0	10.0	10.0	10.0	4.5	2.7	2.0	1.8	1.9	2.8
12	10.0	10.0	10.0	10.0	10.0	3.8	2.3	1.7	1.5	1.6	1.9	2.3
14	10.0	10.0	10.0	10.0	10.0	3.2	1.9	1.4	1.3	1.4	1.6	2.0
16	10.0	10.0	10.0	10.0	10.0	2.8	1.7	1.3	1.1	1.2	1.4	1.7
18	10.0	10.0	10.0	10.0	9.8	2.5	1.5	1.1	1.0	1.1	1.2	1.5
20	10.0	10.0	10.0	10.0	8.8	2.2	1.3	1.0	0.9	0.9	1.1	1.4

MAXIMUM ATTACHMENT SPACING TO ROOF DECK (FT.) GROUND SNOW = 40 PSF												
DIST. TO RIDGE (FT)	ROOF PITCH											
	1:12	2:12	3:12	4:12	5:12	6:12	7:12	8:12	9:12	10:12	11:12	12:12
2	10.0	10.0	10.0	10.0	10.0	6.1	3.7	2.8	2.5	2.7	3.0	3.8
4	10.0	10.0	10.0	10.0	10.0	3.0	1.8	1.4	1.2	1.3	1.5	1.9
6	10.0	10.0	10.0	10.0	7.9	2.0	1.2	0.9	0.8	0.9	1.0	1.2
8	10.0	10.0	10.0	10.0	5.9	1.5	0.9	0.7	0.6	0.6	0.7	0.9
10	10.0	10.0	10.0	10.0	4.7	1.2	0.7	0.5	0.5	0.5	0.6	0.7
12	10.0	10.0	10.0	10.0	3.9	1.0	0.6	0.4	0.4	0.4	0.5	0.6
14	10.0	10.0	10.0	10.0	3.4	0.8	0.5	0.4	0.3	0.3	0.4	0.5
16	10.0	10.0	10.0	10.0	2.9	0.7	0.4	0.3	0.3	0.3	0.3	0.4
18	10.0	10.0	10.0	10.0	2.6	0.6	0.4	0.3	0.2	0.3	0.3	0.4
20	10.0	10.0	10.0	10.0	2.3	0.6	0.3	0.2	0.2	0.2	0.3	0.3

MAXIMUM ATTACHMENT SPACING TO RAFTER (FT.) GROUND SNOW = 40 PSF												
DIST. TO RIDGE (FT)	ROOF PITCH											
	1:12	2:12	3:12	4:12	5:12	6:12	7:12	8:12	9:12	10:12	11:12	12:12
2	10.0	10.0	10.0	10.0	10.0	10.0	8.7	6.5	5.9	6.2	7.1	8.9
4	10.0	10.0	10.0	10.0	10.0	10.0	7.1	4.3	3.2	2.9	3.1	3.5
6	10.0	10.0	10.0	10.0	10.0	10.0	4.7	2.9	2.1	1.9	2.0	2.3
8	10.0	10.0	10.0	10.0	10.0	10.0	3.5	2.1	1.6	1.4	1.5	1.7
10	10.0	10.0	10.0	10.0	10.0	2.8	1.7	1.3	1.1	1.2	1.4	1.7
12	10.0	10.0	10.0	10.0	9.2	2.3	1.4	1.0	0.9	1.0	1.1	1.4
14	10.0	10.0	10.0	10.0	7.8	2.0	1.2	0.9	0.8	0.8	1.0	1.2
16	10.0	10.0	10.0	10.0	6.9	1.7	1.0	0.8	0.7	0.7	0.8	1.1
18	10.0	10.0	10.0	10.0	6.1	1.5	0.9	0.7	0.6	0.6	0.7	0.9
20	10.0	10.0	10.0	10.0	5.5	1.4	0.8	0.6	0.5	0.6	0.7	0.8

MAXIMUM ATTACHMENT SPACING TO ROOF DECK (FT.) GROUND SNOW = 60 PSF												
DIST. TO RIDGE (FT)	ROOF PITCH											
	1:12	2:12	3:12	4:12	5:12	6:12	7:12	8:12	9:12	10:12	11:12	12:12
2	10.0	10.0	10.0	10.0	10.0	4.1	2.5	1.8	1.7	1.8	2.0	2.5
4	10.0	10.0	10.0	10.0	7.9	2.0	1.2	0.9	0.8	0.9	1.0	1.2
6	10.0	10.0	10.0	10.0	5.3	1.3	0.8	0.6	0.5	0.6	0.6	0.8
8	10.0	10.0	10.0	10.0	3.9	1.0	0.6	0.4	0.4	0.4	0.5	0.6
10	10.0	10.0	10.0	10.0	3.1	0.8	0.5	0.3	0.3	0.3	0.4	0.5
12	10.0	10.0	10.0	10.0	2.6	0.6	0.4	0.3	0.2	0.3	0.3	0.4
14	10.0	10.0	10.0	10.0	2.2	0.5	0.3	0.2	0.2	0.2	0.2	0.3
16	10.0	10.0	10.0	10.0	1.9	0.5	0.3	0.2	0.2	0.2	0.2	0.3
18	10.0	10.0	10.0	10.0	1.7	0.4	0.2	0.2	0.1	0.2	0.2	