



Certificate of Compliance

Certificate: 80055292

Master Contract: 259363

Project: 80055292

Date Issued: 2020-09-10

Issued to: Solectria Renewables, LLC
360 Merrimack St Bldg 9 Flr 2
Lawrence, MA 01843
USA
Attention: Emily Hwang

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Yang (Jason) Lei
Yang (Jason) Lei

PRODUCTS

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Grid Support Transformerless Utility Interactive Inverter.

Models PVI 25TL-208.



Certificate: 80055292
Project: 80055292

Master Contract: 259363
Date Issued: 2020-09-10

APPLICABLE REQUIREMENTS

- CSA C22.2 No. 107.1-16 - Power Conversion Equipment
- *UL 1741 - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Second Edition, Revision Dated February 15, 2018)
- UL1741 CRD - Non-Isolated EPS Interactive PV Inverters Rated Less Than 30Kva (Dated April 26, 2010)
- UL1741 CRD - Grid Support Utility Interactive Interoperability Optional Functions: Prevent Enter Service and Limit Active Power (CA Rule 21, Phase 3, functions 2 and 3) (Dated October 22, 2019)
- CSA TIL M-07 - Interim Certification Requirements for Photovoltaic (PV) DC Arc-Fault Protection (Issue Number 1, March 11, 2013)
- UL 1699B - Photovoltaic (PV) DC Arc-Fault Circuit Protection (First Edition, Dated August 22, 2018)

*Note: Conformity to UL 1741 (Second Edition, Revision Dated February 15,2018) includes compliance with applicable requirements of IEEE 1547-2003(R2008), IEEE 1547a-2014, IEEE 1547.1-2005(R2011), IEEE 1547.1a-2015, California Rule 21, Hawaiian Electric Co. SRD-UL-1741-SA-V1.1 and Supplement SA 8-18.