



Tigo EI Inverter (US) Method of Anti-Islanding

Overview

All Tigo EI Inverters are tested and listed to the UL1741 standard for *Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources*.

A utility or Authority Having Jurisdiction (AHJ) may ask for the specific type of anti-islanding method used by Tigo EI Inverters.



Applicability

Tigo EI Inverter models TSI-3.8k-US, TSI-7.6k-US, and TSI-11.4-US.

Reference

Tigo EI Inverters use the following anti-islanding method:

- Group 2A : Frequency shift with discontinuous or stepped positive frequency feedback

Overview

If you have any questions, please call the Tigo Support Line at [+1 408 402-0802](tel:+14084020802) 6 a.m. to 7 p.m. PST.

Jing Tian
Tigo Energy
Chief Growth Officer