



Certificate of Compliance

Certificate: 70172159

Master Contract: 255045

Project: 80103340

Date Issued: 2022-02-28

Issued to: SHANGHAI CHINT POWER SYSTEMS CO., LTD
3255 Si Xian Rd
Songjiang District,
Shanghai, 201614
CHINA

Attention: Huan Cai

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: *Jason Lei*
Jason Lei

PRODUCTS

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Transformerless Grid Support Utility Interactive Inverter, Models CPS SCH100KTL-DO/US-600, CPS SCH125KTL-DO/US-600, CPS SCH100KTL-DO/US-480, CPS SCH100KTL-AIO/US-600 and CPS SCH125KTL-AIO/US-600, permanently connected.

Notes:

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.



Certificate: 70172159
Project: 80103340

Master Contract: 255045
Date Issued: 2022-02-28

APPLICABLE REQUIREMENTS

- CSA C22.2 No. 107.1-16 - Power Conversion Equipment
- *UL 1741 - Inverters, Converters, Controllers and Interconnection System
Equipment for Use With Distributed Energy Resources (Third Edition, September 28, 2021)
- UL1741 CRD - Non-Isolated EPS Interactive PV Inverters Rated Less Than 30Kva (Dated
April 26, 2010)

*Note: Conformity to UL 1741 (Third Edition, September 28, 2021) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547a-2014, IEEE 1547.1-2005(R2011), IEEE 1547.1a-2015, California Rule 21, Hawaiian Electric Co. SRD-UL-1741-SA-V1.1 and Supplement SA8-18, UL 1741 Supplement SB and IEEE 1547.1-2020 with the SRDs of IEEE 1547-2018, IEEE 1547a-2020 and Hawaiian Electric Co. SRD-V2.0. While the grid support function evaluated according to IEEE 1547.1-2020, the interoperability is verified with SunSpec Modbus communication protocol.