

CERTIFICATE OF COMPLIANCE

Certificate Number 20230825-E341165
Report Reference E341165-20210317
Date 2023-09-27

SB

Issued to: Enphase Energy Inc.
1420 N. McDowell Blvd. Petaluma, CA 94954-6515

This is to certify that representative samples of Photovoltaic Grid Support Utility Interactive Inverter with Rapid Shutdown Functionality

Models: IQ8-60, IQ8PLUS-72, IQ8M-72, IQ8A-72, IQ8H-208-72, IQ8H-240-72, may be f/b -2, -5, -E or -M, may be f/b -ACM, f/b -US, may be f/b -NM, may be f/b -RMA, may be f/b -&, where "&" designates additional characters.

Models IQ8HC-72, IQ8AC-72, IQ8MC-72 may be f/b -2, -5, -E or -M, may be f/b -ACM, f/b -US, may be f/b -NM, may be f/b -RMA, may be f/b -&, where "&" designates additional characters.

Model IQ8X-80 may be f/b -2, -5, -E, or -M, may be f/b -ACM, f/b -US, may be f/b -NM, may be f/b -RMA, may be f/b -&, where "&" designates additional characters

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Page 2

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20230825-E341165
Report Reference E341165-20210317
Date 2023-09-27

SB

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.
Standards for Safety:

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements, Standards for Safety:

UL 1741, Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources, Edition 3, Issue Date 05/19/2023. Including the requirements in UL 1741 Supplement SA and SB.

IEEE 1547, Interconnection and Interoperability of Distributed Energy Resources (DERs) with Associated Electric Power Systems (EPSs) Interfaces, Issue Date 02/15/2018

IEEE 1547.1, IEEE Standard Conformance Test Procedures for Interconnecting Distributed Energy Resources (DERs) with Electric Power Systems (EPSs) Associated Interfaces, Issue Date 03/05/2020.

CSA C22.2 No. 107.1-16, General Use Power Supplies, Edition 4, Issue Date 06/2016

R21: The evaluation to the Standards above provides evidence of compliance to the intent of the existing California Rule 21 Interconnection (references to the past publication of IEEE 1547 standards) and UL1741Table SA1.1 option to use the IEEE 1547.1-2020 and UL1741SB test methods in conjunction with using IEEE 1547-2018 as the SRD under which SA11.2 Normal Ramp Rate is not address. Additional testing was conducted to confirmed compliance to Normal Ramp Rate SA11.2

14H (SA): The evaluation to the Standards above provides evidence of compliance to HECO Rule 14H, SRD V1.0, Interconnection Application.

14H (SB): The evaluation to the Standards above provides evidence of compliance to HECO Rule 14H, SRD V2.0, Interconnection Application.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20230825-E341165
Report Reference E341165-20210317
Date 2023-09-27

SB

Inverter Firmware Version:			
Model	UL 1998 (grid support)	Date	Version/Revision
IQ8-60, IQ8PLUS-72, IQ8M-72, IQ8A-72, IQ8H-208-72, IQ8H-240-72, IQ8HC-72, IQ8AC-72, IQ8MC-72, IQ8X-80	Yes	2022-06-16	V2.45.02
	Yes	2022-08-02	V2.45.04
	Yes	2022-09-09	V2.48.01
	Yes	2023-03-22	V2.51.01
	Yes	2023-03-22	V2.56.01
	Yes	2023-08-25	V2.61.01



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20230825-E341165
Report Reference E341165-20210317
Date 2023-09-27

SB

Appendix A

As permitted by UL1741, 3rd Edition, Table SA1.1, shown below, allows for the evaluation of products using either the UL 1741 SA tests or alternative testing methods using the requirements of IEEE 1547.1-2020 in accordance with IEEE 1547-2018 and IEEE 1547a-2020.

UL1741 SA Test Name	SA Test Section	Comparable IEEE 1547.1-2020 and UL1741 SB Test Section	Subject Inverter complies with SA/IEEE 1547.1-2020
Anti-Islanding Protection	SA8	5.10.2	Pass
Low and High Voltage Ride-Through	SA9	5.4.4, 5.4.7	Pass
Low and High Frequency Ride-Through	SA10	5.5.3, 5.5.4	Pass
Normal Ramp Rates	SA11.2	NA ^a	Pass
Soft-Start Ramp Rates	SA11.4	5.6	Pass
Specified Power Factor	SA12	5.14.3	Pass
Volt/Var Mode	SA13	5.14.4	Pass
Frequency-Watt	SA14	5.15.2	Pass
Volt-Watt	SA15	5.14.9	Pass
Disable Permit Service	SA17	5.6	Pass
Limit Active Power	SA18	5.13	Pass

For the purpose of Grid Support Interactive evaluations, this table provides options to use tests from either the UL 1741 SA or IEEE 1547.1 2020 and UL1741SB.

^a IEEE 1547-2018 and IEEE 1547.1-2020 do not have a requirement for, or test equivalent to, the UL 1741 SA Normal Ramp Rate which is presently a local requirement per California Rule 21 and/or Hawaii 14H which both require compliance with the Normal Ramp Rate test of SA11.2. Additional testing to SA11.2 Normal Ramp Rate has been conducted to demonstrate compliance on this DER.

For Volt/Var Mode (clause 5.14.4 of IEEE 1547.1-2020):

Functional in the following priority modes: active power reactive power



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

