


NOTES: UNLESS OTHERWISE SPECIFIED


- 1. SEE DRAWING NO. CB-00278 AND PROCEDURE P-1000 FOR ASSEMBLY AND TEST INSTRUCTION. PROCEDURES AND ASSEMBLY DRAWINGS ARE FOR INTERNAL USE ONLY.
- 2. ALL TESTING IS PERFORMED IAW BATTERY COUNCIL INTERNATIONAL STANDARDS.
- 3. ALL DIMENSIONS ARE INCH [MM].






CAPACITY RATINGS									
PART NUMBER	GPL-24T								
NOMINAL WEIGHT	56 LBS [25.5 KG]								
AMPERE HOUR CAPACITY @ 20 HOUR 1.75 VOLTS/CELL @ 77°F (25°C)	80 AH								
MINUTES OF DISCHARGE @ 25 AMPS 1.75 VOLTS/CELL @ 77°F (25°C)	149 MIN								





ISOMETRIC VIEW



ENVELOPE DRAWING

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ARE:			CONTRACT NO.			CONCORDE BATTERY CORPORATION 2009 SAN BERNARDINO RD, W. COVINA, CA 91790							
±1/32 .XX ± .06 .XXX ± .060		APF	PROVALS	DATE	TITLE								
			±1°	DRAWN	ELH	3/13/00		BAT	TERY,	, 12 VO	LT, GPL-24	4T	
TREATMENT	NONE	<u> </u>		CHECKED	S. VALDEZ	3/13/00	SIZE	CAGE CODE		DWG NO.			REV
FINISH	NONE	Ē.		APPROVED	JBT	3/16/00	C	630	017	DWG NO.	GPL-24T		B
SIMILAR TO		CALC W	VT	ISSUED	AT	6/29/18	SCA	E 1:2.5			SHEET 1	OF	1