



Certificate: 80101839
Project: 80101839

Master Contract: 273488
Date Issued: 2022-10-15

****UL1741 CRD** - (First Edition, Revision Dated August 22, 2018)
Non-Isolated EPS Interactive PV Inverters Rated Less Than 30kVA
(Dated April 26, 2010)

***Note:** Conformity to UL 1741(Third Edition, Dated September 28, 2021) and Grid support function is verified according to UL 1741 Supplement SB and IEEE 1547.1-2020 with the SRDs of IEEE 1547-2018 and IEEE 1547a-2020. While the grid support function evaluated according to IEEE 1547.1-2020, the interoperability is verified with IEEE 2030.5-2018 communication protocol.

****Note:** The functional safety has been evaluated according to applicable requirement of UL 1998-Edition 3 as required by the product standard.

Notes:

Products certified under Class C531109 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 80101839

Master Contract: 273488

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80101839	2022-10-15	Transformerless Grid Support Utility Interactive PV Inverter, Models Solis-1P6K-4G-US, Solis-1P7K-4G-US, Solis-1P7.6K-4G-US, Solis-1P8K-4G-US, Solis-1P8.6K-4G-US, Solis-1P9K-4G-US and Solis-1P10K-4G-US. (C/US)